

**Executive Order VR-101-B**

**Exhibit 1**

**Figure 1A**

**Phil-Tite Phase I Vapor Recovery System Equipment List**

<b>Component Name</b>	<b>Manufacturer</b>	<b>Model Number</b>
<b>Spill Container</b>	Phil-Tite	85000 Series
<b>Debris Bucket</b>	Phil-Tite	PP 1005 TB (product) (required)
	Phil-Tite	PP 1005 TBP (vapor) (optional)
<b>Gasoline Hand Pump</b>	Phil-Tite	EP-400-VB (optional)
<b>Rotatable Phase I Adaptors</b>	Phil-Tite	SWF-100-B (product)
	Phil-Tite	SWV-101-B (vapor)
<b>Phase I Vapor Riser Offset</b>	Phil-Tite	M-6050 (optional)
<b>Riser Adaptor</b>	Phil-Tite	M/F4X4
<b>Spill Container Cast Lid</b>	Phil-Tite	85011
<b>Drop Tube</b>	OPW	61-T (various lengths)
<b>Dust Caps</b>	Morrison Brothers	305C (product)
	Morrison Brothers	323C (vapor)
<b>Pressure/Vacuum Vent Valve</b>	Husky	Model 4885, 2-Inch Threaded
<b>Extractor Fitting</b>	Universal	V421 Series
	OPW	233 Series
<b>Ball Float Vent Valve</b>	Universal	Model 37 Series
	OPW	Model 53 VM Series
<b>Tool Kit for Rotatable Adaptors and Spill Containers</b>	Phil-Tite	T-7043
<b>Tank Gauge Port Components *</b>	Ever-Tite	4097AGBR (Threaded Adaptor) 4097MBR (Double Handle Cap)
<i>* Tank gauge port components, other than those listed above shall <u>not</u> be installed after September 1, 2002. Tank gauge port components installed prior to September 1, 2002, shall be allowed to remain in use for the remainder of their useful life.</i>		

**Figure 1B**

The following components may not be installed as new or replacement parts after September 1, 2002. These components, if installed prior to September 1, 2002, may remain in use for remainder of their useful life.

<b>Component Name</b>	<b>Manufacturer</b>	<b>Model Number</b>
<b>Drop Tube</b>	EBW	782-204 (various lengths)
	Emco Wheaton	A0020 (various lengths)
<b>Extractor Fitting</b>	EBW	3XX Series
	Emco Wheaton	A0079 Series